



**NOTES**

1. ALL METAL SURFACES ABOVE GROUND SHALL BE DEGREASED AND PAINTED WITH ONE COAT OF RED PRIMER AND TWO COATS OF DEEP BLUE FINISH. (RUSTOLEUM OR APPROVED EQUAL)
2. SEE CONCRETE STANDARDS FOR PADS.
3. THRUST RODS AND/OR REBAR EXPOSED TO SOIL SHALL BE ZINC COATED
4. ALL VALVES WITH OPERATING NUTS MORE THAN 24" DEEP SHALL BE PROVIDED WITH OPERATOR EXTENSIONS PER GPSD NO. 217

NO.	DATE	INITIAL	REVISIONS	CITY OF GRANTS PASS ENGINEERING DIVISION	
2	2/05	FMS	WATER STD DWG UPDATE	4" BLOW-OFF ASS'Y (END OF LINE)	
3	11/10	GLV	CONC STD FOR PADS		
DESIGN: STAFF				SCALE: NONE	DWG. NO. 205-A
DRAWN: FMS				APPROVED: DAP	